

ADDENDUM NO. 01
to the Contract Documents for

**NORTH GREECE FIRE DISTRICT –
ENGLISH ROAD STATION 3**
Issued January 30th, 2025

CHANGES TO THE CONTRACT DOCUMENTS:

1. REPLACE DRAWINGS:
 - A-102 Attic Floor Plan
 - A-110 First Floor Reflected Ceiling Plan
 - A-313 Wall Sections
 - A-314 Wall Sections
 - A-315 Typical Wall Section Details
 - A-316 Wall Section Details
 - A-317 Wall Section Details
 - A-318 Wall Section Details
 - A-319 Wall Section Details
 - A-401 Enlarged Plans & Interior Elevations
 - A-420 Enlarged Plans & Interior Elevations
 - A-501 Roof Details
 - A-600 Door Schedule
2. ADDED SPECIFICATIONS:
 - Front End
 - a. 00 21 14 Supplementary Instructions to Bidders
 - b. 00 31 13 Preliminary Schedule
 - c. 00 41 13 Bid Form – Stipulated Sum
 - d. 00 43 21 Allowance Form
 - e. 01 10 00 Summary
 - f. 01 21 00 Allowances
 - g. 01 50 00 Temporary Facilities and Controls
 - h. 01 51 00 Temporary Utilities
 - Division 22
 - Division 23
 - Division 26
 - Division 27

Prospective Bidders are reminded to acknowledge receipt of this Addendum No. 01 on the Bid Proposal Form.

Below is a narrative of the changes included in the revised/added documents above. It is a general overview of the changes and does not necessarily include all of the changes to the documents.

Drawing changes:

1. A-102 Attic Floor Plan
 - a. Additional wall section added for rear wall of Radio Watch Room tower.
2. A-110 First Floor Reflected Ceiling Plan
 - a. Additional ceiling added at AV Room.
 - b. Removal of ceiling at shaft next to Janitors Closet.
3. A-313 Wall Sections
 - a. Additional wall section added for rear wall of Radio Watch Room tower.
4. A-314 Wall Sections
 - a. Bond beam added above wall opening at second floor mezzanine.
5. A-315 Typical Wall Section Details
 - a. Flute fill added at metal decking at roof.
 - b. Additional structural elements referenced.
 - c. EIFS Taper has been changed to extend beyond masonry.
6. A-316 Wall Section Details
 - a. Additional structural elements referenced.
 - b. Metal ceiling annotation changed for accuracy.
 - c. Weeps added to masonry details.
 - d. Additional details added and revised in public entrance overhang.
7. A-317 Wall Section Details
 - a. Multiple design elements revised and annotated.
 - b. Additional structural elements referenced.
 - c. Flute fill added at metal decking at roof.
8. A-318 Wall Section Details
 - a. Additional structural elements referenced.
 - b. Flute fill added at metal decking at roof.
 - c. Annotations revised for clearer understanding.
 - d. View extended to encompass required detail.
9. A-319 Wall Section Details
 - a. Additional structural elements referenced.
 - b. Flashing detail of View 7 revised and detail added for clarification of condition.
10. A-401 Enlarged Plans & Interior Elevations
 - a. Dimension revised for soffit in ceiling plan.
11. A-420 Enlarged Plans & Interior Elevations
 - a. Bond beam added and referenced at training window.
12. A-501 Roof Details
 - a. View 8 added for clarification of condition.
13. A-600 Door Schedule
 - a. Additions and changes made to aluminum doors.

END OF ADDENDUM NO. 01